

PROPERLY USING THE MHX3 QUICKNOTE

Using the MHX3C

To adjust humidity using your MHX3C, simply turn the dial to the left or right. Turning to the left, towards the number 75, increases humidity output. Turning the dial to the right, or the number 10, decreases the humidity output.

After each adjustment, wait 2-3 days before adjusting again. This is how long it can take for new humidity levels to reach all areas of your home.

Ideal humidity is between 40 and 60%. See additional recommended settings to the right.

At Outside Temperature		Recommended Setting
-20°F	-29°C	15%
-10°F	-23°C	20%
0°F	-18°C	25%
+10°F	-12°C	30%
+20°F	-7°C	35%
+30°F	-1°C	40%

BREATHE HEALTHIER®
GeneralAire®